

**TOWN OF HILLSBOROUGH
2008 SEWER SPILL SUMMARY**

<u>Spill Number</u>	<u>Date</u>	<u>Location</u>	<u>Cause of Spill</u>	<u>Spill Volume (gallons)</u>	<u>Volume Reaching Surface Waters(gal)</u>
1	2/9/2008	Manhole at Exchange Club Park	bed sheet in sewer pipe clogged outfal	850	850
2	7/5/2008	Lakeshore Pump Station	severe rain storm	900	900
3	9/6/2008	Dixie Pump Station	Tropical storm Hannah	2,550	2,550
4	9/6/2008	Lawndale Pump Station	Tropical storm Hannah	1,687	1,687
5	9/6/2008	Rencher St. Pump Station	Tropical storm Hannah	2,250	2,250
6	9/6/2008	Churton Grove Pump Station	Tropical storm Hannah	1,200	1,200
7	9/16/2008	Gold Park	contractor damaged sewer pipeline	12,546	7,200
8	9/26/2008	Dimmocks Mill Rd outfall (Gold Park)	severe rain storm and debris in line	14,400	14,400
9	12/11/2008	Champayne Club Outfall (hayes&spruce)	severe rain storm	300	300
10	12/28/2008	405 Corbin st.	paper towels causing partial blockage	630	630
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
31					

TOTAL 37,313 31,967